

**CITY OF ST. AUGUSTA
STEARNS COUNTY, MINNESOTA
ORDINANCE NO. 2008-01**

AN ORDINANCE AMENDING SECTION 52.30 OF ORDINANCE #2003-09,
RELATED TO DRINKING WATER REGULATIONS
WITHIN THE CITY OF ST. AUGUSTA

THE CITY COUNCIL OF THE CITY OF ST. AUGUSTA, MINNESOTA
HEREBY ORDAINS:

Section 1. Section 52.30 of the Ordinance #2003-09 is hereby repealed and amended to include the following:

52.30 SERVICE PIPES

Every service pipe shall be laid so as to allow at least one foot of extra length in order to prevent rupture by settlement. The service pipe must be placed no less than eight feet below the ground and in a manner as to prevent rupture by freezing. Service pipes must extend from the curb stop box to the inside of the building, or if not taken into the building, then to the hydrant or fixtures which it is intended to supply. Any allowable material (by code) shall be used up to and including two-inch services. All underground joints are to be mechanical, except joints under floors shall be silver soldered, unless otherwise approved by the Public Works Director. Joints of copper tubing shall be kept, to a minimum, with not more than one joint used for service for each 70 feet in length. Splicing may be approved with three-piece unions only. All joints and connections shall be left uncovered until inspected by the Public Works Director and tested at normal water line pressure. Unions must be three-part type. All services over two inches shall be ductile iron. Connections with the mains for domestic supply shall be at least one inch up to the curb stop box. Service connections up to and including curb stop, are to be installed in accordance with City specifications.
Penalty, see § 10.99

Section 2. Enactment. This ordinance shall be in full force and effect upon its passage and publication.

ADOPTED this 3 day of June 2008.

CITY OF ST. AUGUSTA

By: B.J. Kroll
B.J. Kroll, Mayor

ATTEST:

By: William R. McCabe
William R. McCabe, City Administrator